

ADDENDUM 1 BID SC-1914

October 4, 2019

ADDENDUM 1

This is a follow-up sent in regards to SC-1914 One (1) Building Generator for Fort Smith Courthouse:

1. Section IV: Specifications: One (1) total building generator should be:
The Fort Smith Courthouse has 2000 AMP 480/277 Volt 3 phase service with OG&E.

By signing below, vendor agrees to and shall fully comply with all requirements as shown in this Addendum.
Failure to return this signed addendum with your proposal may result in rejection of your response.

Company: _____

Authorized Signature: _____

Printed/Typed Name: _____ Date: _____